



AGA CERTIFIED PRODUCT

JAS-ANZ



www.jas-anz.org/register

Certificate Holder: **SIEMENS LTD**
ABN/ACN No. (if applicable): 98 004 347 880
Manufacturer: **SIEMENS LTD**
Agent (if applicable): N/A
Type of Component: **Independent Flame Detector Device**
Model No. & Description: **SIEMENS**
(Refer www.aga.asn.au for more details)

LFS1.21A1- 120 V AC, 50/60 HZ
LFS1.21A2 - 230 V AC, 50/60 HZ

- Note:
1. Permanent operation with flame ionisation - Class 1A, 1D.
 2. Non-permanent operation with UV flame detectors QRA2, QRA2.9, QRA4.U or QRA10.C Class 2A, 2D, 3D.
 3. AGK30 device must be used when high sensitivity UV flame detector types QRA2M, QRA4M.U or QRA10M.C are connected.
 4. Non-permanent operation with UV flame detectors QRA2M, QRA4M.U or QRA10M.C - Class 2A, 2D, 3D.
 5. Non-permanent operation with flame ionisation simultaneously connected with UV flame detectors QRA2, QRA2.9, QRA4.U, QRA10 or AGK30 and QRA2M, QRA4M.U or QRA10M.C. - Class 2A, 2D, 3D.
 6. Requires parameters to be set with AZL21.009 or AZL23.009 display and operating unit prior to use.
 7. Not for use with any other manufacturer's UV flame detectors.

Relevant Standard(s): **EN 298 – 2012**
AS 4625 – 2008

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Client Manager

Certificate Authorised

Certificate first issued: **20 April 2017**

Certificate No: **8542**

This copy valid from: **31 July 2020**

Refer specification issue: **03**