



Certificate of Compliance

Certificate: 70000619

Master Contract: 162938

Project: 70116726

Date Issued: 2017-03-20

Issued to: Siemens AG
Berliner Ring 23
76437 Rastatt
GERMANY

Attention: Mr. Hermann Hasselbach

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and US Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: Michael Janker
Michael Janker

PRODUCTS

CLASS 2252 05 - PROCESS CONTROL EQUIPMENT

CLASS 2252 85 - PROCESS CONTROL EQUIPMENT - Certified to US Standards

Compact universal temperature / pressure controllers, Models RWF55.50A9, RWF55.51A9, RWF55.60A9, RWF55.61A9 and RWF55XX, rated supply 110-240VAC +10/-15%, 48-63Hz, 20VA, equipped with 4 relay outputs rated 240VAC, 2A, $\cos \phi > 0.6$.

Notes:

1. The above models are an open type devices for incorporation in other equipment providing a Pollution Degree 2, Overvoltage Category III environment.
2. Mode of operation: Continuous.
3. Environmental Conditions: -20 to 50 °C, max 2000m above sea level, < 95% RH.



Certificate: 70000619

Master Contract: 162938

Project: 70116726

Date Issued: 2017-03-20

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements
- UL Std. No. 61010-1 (2nd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

CONDITIONS OF ACCEPTABILITY

- (1) The end-product shall consider that: Only the front portion of the panel-mounted device has been investigated as the ultimate enclosure. The devices were investigated as regulating controls without any calibration tests.
- (2) The need for the following shall be considered in the end-product: MAINS disconnect device.
- (3) The output connectors are: Suitable for field wiring.
- (4) The unit is considered acceptable for use at on a max branch circuit of: 20 A.