

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Actuators for air and gas dampers**with type designation(s)
SQM4x.36xxxx, SQM4x.38xxxx

Issued to

Siemens AG
Rastatt, Germanyis found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

Type	Temperature	Humidity	Vibration
SQM4x.36xxxx	A	A	A
SQM4x.38xxxx	A	A	A

Issued at **Hamburg** on **2020-04-07**for **DNV GL**This Certificate is valid until **2025-04-06**.DNV GL local station: **Essen**Approval Engineer: **Uwe Supke**

Arne Schaarmann
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

The SQM4x.36xxxx and SQM4x.38xxxx actuators are suited for driving flow control valves, butterfly valves, dampers or for use on other applications that require rotary motion.

Operating voltage: AC 230 V -15%/+10%; AC 120 V -15%/+10%

Operating frequency: 50...60 Hz \pm 6%

Drive motor: Synchronous motor

Power consumption: 10 VA

Operating angle: Adjustable between 0 and max. 90°

Degree of protection: IP66

Torque: 18 Nm

Running times: 65 seconds 90°

Internal position indication

Application/Limitation

The Type Approval covers hardware listed under Product description.

Equipment intended to be installed on ships contracted for construction on or after 1 January 2022 is to comply with class guideline DNVGL-CG-0339, December 2019.

Type Approval documentation

[Datasheet_CC1N7817de_V0201.pdf](#); [Test Reports:](#)

[SQM40_387A20_N13611_A7 Funktionsanforderungen_V0100.pdf](#);

[2009-02-24-SQM4x.x6xx2-Funktionsprüfungen_a201.pdf](#);

[387A21-LR-02_GL-03_DNV-01_BV-00_Power Supply Variation_V0100.pdf](#);

[SQM40367A21-LR-02_GL-03_DNV-01_BV-00_Power Supply Variation_V0100.pdf](#);

[SQM40387A21-LR-02_GL-03_DNV-01_BV-00_Dry Heat_V0100.pdf](#);

[SQM40367A21-LR-02_GL-03_DNV-01_BV-00_Dry Heat_V0100.pdf](#);

[K004361_01_2012_M_A01](#); [K003364_01_2009_M_A01](#);

[SQM40387A21-LR-02_GL-03_DNV-01_BV-00_Insulation-Resistance_V0100.pdf](#);

[SQM40367A21-LR-02_GL-03_DNV-01_BV-00_Insulation-Resistance_V0100.pdf](#);

[SQM40387A21-LR-02_GL-03_DNV-01_BV-00_Conducted Low Frequency_V0100.pdf](#);

[SQM40367A21-LR-02_GL-03_DNV-01_BV-00_Conducted Low Frequency_V0100.pdf](#)

[Type approval renewal assessment report for, DNV GL Augsburg 2019-12-02](#)

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

Marking of product

The products to be marked with:


- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications



Job Id: **262.1-032671-1**
Certificate No: **TAE00003Y3**

- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE